Tracking Well Performance through the 100-year life of a Water Well



Kathy Tixier, GM Jim Clark, Fraser Valley Regional Director



- Less than 10% of Fraser Valley farmers know what their pumping water level is..
- Lack of good record keeping makes it difficult for well owners and their contractors to make good decisions
- Routine installation of sounding tubes and repeated water level and specific capacity measurements would improve the situation

Objectives

- Educate people working with wells about the lifecycle of a well
- Identify contractors' and owners roles in the process
- Promote record keeping to inform good management decisions
 - e.g. locating, deepening, rehabilitating, licensing a well





Contractors can make SC measurements possible by installing a **Sounding tube**

- A 1¼ inch tube certified for use for drinking water
- Secure tube to riser pipe
- Extend to the top of pump
- Put elbow on bottom of tube to prevent loss of down-hole equipment





Not so Good

Good

A Sounding Tube can also be used to:

- 1. Measure water levels during a flow test
- 2. Monitor pumping level when the well is operating
- 3. Monitor static water level when the well is at rest
- 4. House a permanent water level transducer and other sensing equipment
- 5. Measure drawdown interference from when neighboring well are operated
- 6. Inject chlorine to bottom of well during well disinfection
- 7. And so on...



Water Well Life Cycle Stages

• Each stage represented by an orb



• Each trade represented by a colour

The Well Construction Stage

DRILL

Pump installer recommends pump size (and well diameter) to meet target flows Consultants may be involved in siting the well

Driller designs and constructs well, conducts short flow tests during well development

The Flow Testing Stage

Driller roughly estimates specific capacity to help size pump for flow test



Water samples may also be collected at this step to evaluate water quality



Pump Installer conducts variable-rate flow test to properly measure baseline specific capacity





WELL IS NOW OPERATIONAL

Well owner is given important documentation:

- Water well record
- Flow test results
- Permanent pump set record
- Water quality lab results

And should monitor static and pumping water levels



Borehole / Well Construction Log



Pump Set Record



Well Pumping Test Data



		Reference Number Sample Date Sample Time Sample Location	1031309-1 October 07, 2 07:45	2014		
		Sample Description Sample Matrix	3233 Celtic Ave. Vancouver BC Drinking Water			
Analyte		Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
Inorganic Nonmetallic P	arameters					
Tannin & Lignin	as Tannic Acid	mg/L	12.9	0.1		
Metals Extractable						
Aluminum	Extractable	mg/L	0.073	0.005	0.1	Below OG
Antimony	Extractable	mg/L	<0.0002	0.0002	0.006	Below MAC
Arsenic	Extractable	mg/L	0.0022	0.0002	0.010	Below MAC
Barium	Extractable	ma/l	0 021	0 001	1	Below MAC
Boron			•	1.1	5	Below MAC
Cadmium	aram	eters re	niin	red hv	0.005	Below MAC
Chromium	arann		- y u i	CGNY	0.05	Below MAC
Copper					1.0	Below AO
Lead		oolth A	utho	nrit y	0.01	Below MAC
Selenium			MULIC		0.01	Below MAC
I Incomission					0.00	Delew MAG
Uranium				,	0.02	Below MAC
Uranium Vanadium Zina	Extractable	mg/∟	U.U245	0.0001	0.02	Below MAC
Uranium Vanadium Zinc	Extractable Extractable	mg/L mg/L	0.0245 0.004	0.0001 0.001	0.02 5.0	Below MAC Below AO
Uranium Vanadium Zinc Physical and Aggregate	Extractable Extractable Properties	mg/L Colour units	0.0245 0.004	0.0001 0.001	0.02 5.0	Below MAC Below AO
Uranium Vanadium Zinc Physical and Aggregate Colour Turbidity	Extractable Extractable Properties Apparent	rng/L mg/L Colour units	0.0245 0.004 >150 2.2	0.0001 0.001 5 0.02	0.02 5.0	Below MAC Below AO
Uranium Vanadium Zinc Physical and Aggregate Colour Turbidity Poutino Water	Extractable Extractable Properties Apparent	mg/L mg/L Colour units NTU	0.0245 0.004 >150 3.2	0.0001 0.001 5 0.02	0.02 5.0	Below MAC Below AO
Uranium Vanadium Zinc Physical and Aggregate Colour Turbidity Routine Water	Extractable Extractable Properties Apparent	mg/L mg/L Colour units NTU	0.0245 0.004 >150 3.2 7.18	0.0001 0.001 5 0.02	0.02	Below MAC Below AO
Uranium Vanadium Zinc Physical and Aggregate Colour Turbidity Routine Water pH Electrical Conductivity	Extractable Extractable Properties Apparent at 25 °C	ing/L mg/L Colour units NTU	0.0240 0.004 >150 3.2 7.18 2750	0.000 0.001 5 0.02	0.02 5.0 6.5-8.5	Below MAC Below AO Within AO
Uranium Vanadium Zinc Physical and Aggregate Colour Turbidity Routine Water pH Electrical Conductivity Calcium	Extractable Extractable Properties Apparent at 25 °C Extractable	rng/L mg/L Colour units NTU μS/cm at 25 C mg/l	0.0240 0.004 >150 3.2 7.18 2750 17.7	0.0001 5 0.02 1 0.1	0.02 5.0 6.5-8.5	Below MAC Below AO Within AO
Uranium Vanadium Zinc Physical and Aggregate Colour Turbidity Routine Water pH Electrical Conductivity Calcium	Extractable Extractable Properties Apparent at 25 °C Extractable Extractable	rng/L mg/L Colour units NTU μS/cm at 25 C mg/L mg/l	0.0240 0.004 >150 3.2 7.18 2750 17.7 4.08	0.0001 5 0.02 1 0.1 0.05	0.02 5.0 6.5-8.5	Below MAC Below AO Within AO
Uranium Vanadium Zinc Physical and Aggregate Colour Turbidity Routine Water pH Electrical Conductivity Calcium Iron Magnesium	Extractable Extractable Properties Apparent at 25 °C Extractable Extractable Extractable	rrrg/L mg/L Colour units NTU μS/cm at 25 C mg/L mg/L mg/L	0.0240 0.004 >150 3.2 7.18 2750 17.7 4.08 53.9	0.0001 5 0.02 1 0.1 0.005 0.1	0.02 5.0 6.5-8.5 0.3	Below MAC Below AO Within AO Above AO
Uranium Vanadium Zinc Physical and Aggregate Colour Turbidity Routine Water pH Electrical Conductivity Calcium Iron Magnesium Magnesium	Extractable Extractable Properties Apparent at 25 °C Extractable Extractable Extractable Extractable	rrig/L mg/L Colour units NTU μS/cm at 25 C mg/L mg/L mg/L mg/L mg/L	0.0245 0.004 >150 3.2 7.18 2750 17.7 4.08 53.9 0.119	0.001 5 0.02 1 0.05 0.1 0.001	0.02 5.0 6.5-8.5 0.3 0.05	Below MAC Below AO Within AO Above AO
Uranium Vanadium Zinc Physical and Aggregate Colour Turbidity Routine Water pH Electrical Conductivity Calcium Iron Magnesium Manganese Potassium	Extractable Extractable Properties Apparent at 25 °C Extractable Extractable Extractable Extractable Extractable	rrig/L mg/L Colour units NTU μS/cm at 25 C mg/L mg/L mg/L mg/L mg/L mg/L	0.0245 0.004 >150 3.2 7.18 2750 17.7 4.08 53.9 0.119 26.6	0.0001 0.001 5 0.02 1 0.1 0.005 0.1 0.001 0.1	0.02 5.0 6.5-8.5 0.3 0.05	Below MAC Below AO Within AO Above AO Above AO
Uranium Vanadium Zinc Physical and Aggregate Colour Turbidity Routine Water pH Electrical Conductivity Calcium Iron Magnesium Manganese Potassium	Extractable Extractable Properties Apparent at 25 °C Extractable Extractable Extractable Extractable Extractable Extractable	rrigrL mg/L Colour units NTU μS/cm at 25 C mg/L mg/L mg/L mg/L mg/L mg/L mg/L	0.0245 0.004 >150 3.2 7.18 2750 17.7 4.08 53.9 0.119 26.6 20 7	0.000 0.001 5 0.02 1 0.1 0.005 0.1 0.001 0.1 0.05	0.02 5.0 6.5-8.5 0.3 0.05	Below MAC Below AO Within AO Above AO Above AO
Uranium Vanadium Zinc Physical and Aggregate Colour Turbidity Routine Water pH Electrical Conductivity Calcium iron Magnesium Manganese Potassium Silicon Sodium	Extractable Extractable Properties Apparent at 25 °C Extractable Extractable Extractable Extractable Extractable Extractable Extractable	rng/L mg/L Colour units NTU μS/cm at 25 C mg/L mg/L mg/L mg/L mg/L mg/L mg/L mg/L	0.0240 0.004 >150 3.2 7.18 2750 17.7 4.08 53.9 0.119 26.6 20.7 535	0.0001 0.001 5 0.02 1 0.1 0.005 0.1 0.001 0.1 0.05 0.1	0.02 5.0 6.5-8.5 0.3 0.05 200	Below MAC Below AO Within AO Above AO Above AO
Uranium Vanadium Zinc Physical and Aggregate Colour Turbidity Routine Water pH Electrical Conductivity Calcium (fron Magnesium Manganese Potassium Silicon Sodium T-Alkalinity	Extractable Extractable Properties Apparent at 25 °C Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable	IngrL mg/L Colour units NTU µS/cm at 25 C mg/L mg/L mg/L mg/L mg/L mg/L mg/L mg/L	0.0245 0.004 >150 3.2 7.18 2750 17.7 4.08 53.9 0.119 26.6 20.7 535 583	0.0001 5 0.02 1 0.1 0.005 0.1 0.001 0.1 0.05 0.1 5	0.02 5.0 6.5-8.5 0.3 0.05 200	Below MAC Below AO Within AO Above AO Above AO
Uranium Vanadium Zinc Physical and Aggregate Colour Turbidity Routine Water pH Electrical Conductivity Calcium fron Magnesium Manganese Potassium Silicon Sodium T-Alkalinity Chloride	Extractable Extractable Properties Apparent at 25 °C Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable	rrig/L mg/L Colour units NTU μS/cm at 25 C mg/L mg/L mg/L mg/L mg/L mg/L mg/L mg/L	0.0245 0.004 >150 3.2 7.18 2750 17.7 4.08 53.9 0.119 26.6 20.7 535 583 205	0.0001 5 0.02 1 0.1 0.005 0.1 0.001 0.1 0.05 0.1 5 0.05 0.1 5 0.05 0.1	0.02 5.0 6.5-8.5 0.3 0.05 200 250	Below MAC Below AO Within AO Above AO Above AO Below AO
Uranium Vanadium Zinc Physical and Aggregate Colour Turbidity Routine Water pH Electrical Conductivity Calcium Iron Magnesium Manganese Potassium Silicon Sodium T-Alkalinity Chloride Eluoride	Extractable Extractable Properties Apparent at 25 °C Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable	IIIg/L mg/L Colour units NTU µS/cm at 25 C mg/L mg/L mg/L mg/L mg/L mg/L mg/L mg/L	0.0245 0.004 >150 3.2 7.18 2750 17.7 4.08 53.9 0.119 26.6 20.7 535 583 205 0.63	0.0001 0.001 5 0.02 1 0.1 0.005 0.1 0.05 0.1 5 0.05 0.1 5 0.05 0.1	0.02 5.0 6.5-8.5 0.3 0.05 200 250 1.5	Below MAC Below AO Within AO Above AO Above AO Below AO Below AO
Uranium Vanadium Zinc Physical and Aggregate Colour Turbidity Routine Water pH Electrical Conductivity Calcium Iron Magnesium Magnesium Sodium T-Alkalinity Chloride Fluoride Nitrate - N	Extractable Extractable Properties Apparent at 25 °C Extractable Dissolved Dissolved	rrig/L mg/L Colour units NTU µS/cm at 25 C mg/L mg/L mg/L mg/L mg/L mg/L mg/L mg/L	0.0245 0.004 >150 3.2 7.18 2750 17.7 4.08 53.9 0.119 26.6 20.7 535 583 205 0.63 <010	0.000 0.001 5 0.02 1 0.1 0.005 0.1 0.05 0.1 5 0.05 0.1 5 0.05 0.01 0.01	0.02 5.0 6.5-8.5 0.3 0.05 200 250 1.5 10	Below MAC Below AO Within AO Above AO Above AO Below AO Below MAC Below MAC
Uranium Vanadium Zinc Physical and Aggregate Colour Turbidity Routine Water pH Electrical Conductivity Calcium Iron Magnesium Manganese Potassium Silicon Sodium T-Alkalinity Chloride Fluoride Nitrate - N	Extractable Properties Apparent at 25 °C Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Extractable Dissolved Dissolved Dissolved	rrig/L mg/L Colour units NTU µS/cm at 25 C mg/L mg/L mg/L mg/L mg/L mg/L mg/L mg/L	0.0245 0.004 >150 3.2 7.18 2750 17.7 4.08 53.9 0.119 26.6 20.7 535 583 205 0.63 <0.10 <0.10	0.0001 0.001 5 0.02 1 0.1 0.005 0.1 0.001 0.1 5 0.05 0.1 5 0.05 0.1 5 0.05 0.1 0.01 0.01	0.02 5.0 6.5-8.5 0.3 0.05 200 250 1.5 10 1	Below MAC Below AO Within AO Above AO Above AO Below AO Below MAC Below MAC Below MAC
Uranium Vanadium Zinc Physical and Aggregate Colour Turbidity Routine Water pH Electrical Conductivity Calcium fron Magnesium Manganese Potassium Silicon Sodium T-Alkalinity Chloride Fluoride Nitrate - N Nitrite - N Suffate (SO4)	Extractable Extractable Properties Apparent at 25 °C Extractable Dissolved Dissolved Dissolved	mg/L mg/L Colour units NTU µS/cm at 25 C mg/L mg/L mg/L mg/L mg/L mg/L mg/L mg/L	0.0245 0.004 >150 3.2 7.18 2750 17.7 4.08 53.9 0.119 26.6 20.7 535 583 205 0.63 <0.10 <0.10 611	0.0001 0.001 5 0.02 1 0.1 0.005 0.1 0.001 0.1 0.05 0.1 5 0.05 0.01 0.01 0.01 0.5	0.02 5.0 6.5-8.5 0.3 0.05 200 250 1.5 10 1 500	Below MAC Below AO Within AO Above AO Above AO Below AAO Below MAC Below MAC Below MAC Below MAC
Uranium Vanadium Zinc Physical and Aggregate Colour Turbidity Routine Water pH Electrical Conductivity Calcium fron Magnesium Manganese Potassium Silicon Solium T-Alkalinity Chloride Fluoride Fluoride Nitrate - N Nitrite - N Sulfate (SO4) Hardness	Extractable Extractable Properties Apparent at 25 °C Extractable Dissolved Dissolved Dissolved Dissolved Dissolved Dissolved	riig/L mg/L Colour units NTU µS/cm at 25 C mg/L mg/L mg/L mg/L mg/L mg/L mg/L mg/L	0.0245 0.004 >150 3.2 7.18 2750 17.7 4.08 53.9 0.119 26.6 20.7 535 583 205 0.63 <0.10 <0.10 <11 266	0.0001 5 0.02 1 0.1 0.005 0.1 0.001 0.1 0.05 0.1 5 0.05 0.01 0.05 0.01 0.01 0.01 0.05 0.1 1 1 1 1 1 1 1 1 1 1 1 1 1	0.02 5.0 6.5-8.5 0.3 0.05 200 250 1.5 10 1 500	Below MAC Below AO Within AO Above AO Above AO Below AO Below MAC Below MAC Below MAC Below MAC

Water Quality Testing Laboratory Report



MONITORING DATA IDENTIFIES DECLINING WELL PERFORMANCE

- Sediment packing
- Biofouling
- Chemical encrustation





Causes of performance decline vary... ... As do the remedies to these causes

- Mechanical
- Chemical
- **Impulse Generation**

Owner and consultant identify problem and formulate a plan to service the well

Pump installer conducts flow tests to gauge rehabilitation success WELL #1

Well rehabilitator (Pump Installer or Driller) services the well

WELL OPERATION RESUMES

Well owner is given important documentation:

- Current specific capacity measurements
- Recent flow test results
- Permanent pump set record, if changed
- Water quality lab results, if additional

MONITORING DATA IDENTIFIES DECLINING WELL PERFORMANCE (AGAIN)

Owner and consultant identify problem and formulate a plan to service the well

Well rehabilitator (Pump Installer or Driller) services the well

WELL OPERATION RESUMES

Well owner is given important documentation:

- Current specific capacity measurements
- Recent flow test results
- Permanent pump set record, if changed
- Water quality lab results, if additional

And should continue collecting operational data

MONITORING DATA IDENTIFIES DECLINING WELL PERFORMANCE (AGAIN)

Owner and consultant decide to decommission the well

Owner submits closure report to the Ministry

Pump Installer or Driller decommission the well

The Complete Water Well Life Cycle (60 – 100 years)

The Complete Water Well Life Cycle (60 – 100 years)

Specific Capacity should be measured and recorded throughout this cycle....

CASE EXAMPLE

- 300 foot well
- Client wants to pump the well at 100 gpm
- Static water 15ft below top of casing

HOW DO WE DETERMINE WHERE TO SET THE PUMP?

Driller's Well Yield Test

Specific Capacity at 25 gpm: = 25 gpm / 15 ft drawdown = **1.6** gpm/ft

Estimated drawdown at 100 gpm: = 100 gpm / 1.6 gpm/ft = 63 ft

Estimated Pumping water level = 63 + 15 = **78 ft** below casing

SC can drop significantly with increasing pumping rate in some settings

Specific Capacity values should be compared to the original to SC's to gauge changes in well performance

Standard practice is to rehabilitate after 25% drop in SC, sometimes sooner

Months to many years

Specific Capacity measurements before, during and after well rehabilitation help to gauge rehabilitation success

RECORD OF WELL SERVICE #1

Specific capacity measurements also show when well closure is more appropriate...

Q = 100 gpm

Months to many years

Static (non-pumping) water level measurements tell us what is happening in aquifer

Measure frequently or continuously

Measure with a water level sounder or similar device

Record datum from which level is measured (e.g. top of well casing)

Interwell drawdown interferences from neighbouring wells

Contractors and consultants record information for the file, and educate well owners on the importance of continuing to monitor water levels and specific capacity

Well Owners need to keep track of this information

- Well logs, construction reports
- Pump test records
- Pump set records
- Static / Pumping Water Level Data
- Past invoices, contact info
- Water quality analyses
- Photos / videos

Equipment model and serial numbers (pump, transducers, electrical components)

Closing Remarks

- Drillers and Pump Installers are on the 'front lines' with well owner
- Water levels and specific capacity are important indicators of well and aquifer health
- Good information makes for good decision-making
- We each have a role to play in the water well life cycle

THANK YOU

